

Fire Log 2013-2014

<u>Date</u>	<u>Time</u>	<u>Building/Grounds</u>	<u>Location</u>	<u>Nature</u>	<u>Cause</u>	<u>Intentional</u>
5/31/2013	7:00 PM	Simperman	Scola Lounge	BBQ Smoke		no
8/27/2013	7:30 AM	Trinity Hall	Student Room	Hair Dryer Smoke		no
9/9/2013	6:00 PM	Guadalupe Hall	Ground Floor Restroom	Smoke	Singed Toilet Paper	no (no alarm, reported to staff)
10/10/2013		Guadalupe Hall		scheduled fire drill		
10/10/2013		St. Charles		scheduled fire drill		
10/10/2013		Borromeo Hall		scheduled fire drill		
10/10/2013		Trinity Hall		scheduled fire drill		
12/8/2013	6:00 PM	Borromeo Hall	Student Room	alarm triggered	unknown	no
2/19/2014		Guadalupe Hall		scheduled fire drill, alarm set off at 1:05, evacuation complete at 1:13 pm		
2/19/2014		St. Charles		scheduled fire drill, alarm set off at 1:25, evacuation complete at 1:34 pm		
2/19/2014		Borromeo Hall		scheduled fire drill, alarm set off at 1:40, evacuation complete at 1:46		
2/19/2014		Trinity Hall		scheduled fire drill, alarm set off at 1:58, evacuation complete at 2:06 pm		
2/19/2014	2:15 PM	Trinity Hall	Student Room	during scheduled fire drill, student did not leave the building		
2/19/2014	2:05	Borromeo Hall	Hallway	during scheduled fire drill, stu student did not leave the building in a timely manner		
3/5/2014	4:35	Nelson Stadium	stadium	alarm triggered	water line broke	no
4/12/2014	11:05 AM	Trinity Hall	Rm 310	alarm triggered	hair dryer	no
4/15/2014	10:00 PM	Borromeo Hall	Rm 211	alarm triggered	alarm system box	no
5/12/2014	12:41 AM	Trinity Hall	Rm 121	alarm triggered twice	unknown	no
6/8/2014	8:58 PM	Science Building	3rd floor	alarm triggered	dusty smoke detecto	no
7/8/2014	7:53 PM	Trinity Hall	3rd floor	alarm triggered	cooking burgers	no
7/19/2014	10:54 PM	Borromeo Hall		alarm triggered	device tampering	unknown

(updated by TH 7.19.14)